

석면농도측정 결과표

(Asbestos and other fibers by PCM)

측 정 결 과							
Sample no	Process	Flow(ℓ)	Time(min)	Total Vol(ℓ/min)	Total Fiber	섬유농도 Conc.(f/cc)	노출기준
WL-01	4층 창고a	13.47	90	1,212.3	12	0.0049	0.01 f/cc
WL-02	4층 창고b	13.51	90	1,215.9	15	0.0061	0.01 f/cc
WL-03	4층 창고c	13.49	90	1,214.1	14	0.0057	0.01 f/cc
WL-04	4층 복도a	13.45	90	1,210.5	14	0.0057	0.01 f/cc
WL-05	4층 계단실	13.44	90	1,209.6	13	0.0053	0.01 f/cc
WL-06	4층 복도c	13.48	90	1,213.2	15	0.0061	0.01 f/cc
WL-07	4층 복도d	13.45	90	1,210.5	16	0.0065	0.01 f/cc
WL-08	4층 복도e	13.48	90	1,213.2	17	0.0069	0.01 f/cc
WL-09	4층 연구실a	13.52	90	1,216.8	11	0.0044	0.01 f/cc
WL-10	4층 연구실b	13.51	90	1,215.9	10	0.0040	0.01 f/cc
WL-11	4층 6-1a	13.49	90	1,214.1	10	0.0040	0.01 f/cc
WL-12	4층 6-1b	13.49	90	1,214.1	9	0.0036	0.01 f/cc
WL-13	4층 6-1c	13.54	90	1,218.6	9	0.0036	0.01 f/cc
WL-14	4층 6-2a	13.47	90	1,212.3	8	0.0032	0.01 f/cc
WL-15	4층 6-2b	13.48	90	1,213.2	9	0.0036	0.01 f/cc
WL-16	4층 6-3c	13.52	90	1,216.8	9	0.0036	0.01 f/cc
WL-17	3층 창고a	14.48	90	1,303.2	14	0.0053	0.01 f/cc
WL-18	3층 창고b	14.45	90	1,300.5	13	0.0049	0.01 f/cc
WL-19	3층 창고c	14.49	90	1,304.1	14	0.0053	0.01 f/cc
WL-20	3층 복도a	14.44	90	1,299.6	15	0.0057	0.01 f/cc

석면농도측정 결과표

(Asbestos and other fibers by PCM)

측 정 결 과

Sample no	Process	Flow(ℓ)	Time(min)	Total Vol(ℓ/min)	Total Fiber	섬유농도 Conc.(f/cc)	노출기준
WL-21	3층 복도b	14.41	90	1,296.9	14	0.0053	0.01 f/cc
WL-22	3층 복도c	14.43	90	1,298.7	16	0.0060	0.01 f/cc
WL-23	3층 복도d	14.41	90	1,296.9	15	0.0057	0.01 f/cc
WL-24	3층 복도e	14.48	90	1,303.2	14	0.0053	0.01 f/cc
WL-25	3층 연구실a	14.44	90	1,299.6	11	0.0042	0.01 f/cc
WL-26	3층 연구실b	14.47	90	1,302.3	12	0.0045	0.01 f/cc
WL-27	3층 5-1a	14.45	90	1,300.5	9	0.0034	0.01 f/cc
WL-28	3층 5-1b	14.48	90	1,303.2	8	0.0030	0.01 f/cc
WL-29	3층 5-1c	14.49	90	1,304.1	9	0.0034	0.01 f/cc
WL-30	3층 5-2a	14.45	90	1,300.5	10	0.0038	0.01 f/cc
WL-31	3층 5-2b	14.47	90	1,302.3	8	0.0030	0.01 f/cc
WL-32	3층 5-2c	14.45	90	1,300.5	9	0.0034	0.01 f/cc
WL-33	3층 5-3a	14.49	90	1,304.1	10	0.0038	0.01 f/cc
WL-34	3층 5-3b	14.51	90	1,305.9	10	0.0038	0.01 f/cc
WL-35	3층 5-3c	14.48	90	1,303.2	10	0.0038	0.01 f/cc
WL-36	2층 어학실a	14.47	90	1,302.3	9	0.0034	0.01 f/cc
WL-37	2층 어학실b	14.49	90	1,304.1	8	0.0030	0.01 f/cc
WL-38	2층 어학실c	14.45	90	1,300.5	10	0.0038	0.01 f/cc
WL-39	2층 복도a	14.47	90	1,302.3	14	0.0053	0.01 f/cc
WL-40	2층 복도b	14.48	90	1,303.2	15	0.0056	0.01 f/cc

석면농도측정 결과표

(Asbestos and other fibers by PCM)

측 정 결 과							
Sample no	Process	Flow(ℓ)	Time(min)	Total Vol(ℓ/min)	Total Fiber	섬유농도 Conc.(f/cc)	노출기준
WL-41	2층 복도c	14.49	90	1,304.1	13	0.0049	0.01 f/cc
WL-42	2층 복도d	14.52	90	1,306.8	15	0.0056	0.01 f/cc
WL-43	2층 복도e	14.46	90	1,301.4	15	0.0057	0.01 f/cc
WL-44	2층 연구실a	14.45	90	1,300.5	13	0.0049	0.01 f/cc
WL-45	2층 연구실b	14.43	90	1,298.7	11	0.0042	0.01 f/cc
WL-46	2층 1-7a	14.47	90	1,302.3	10	0.0038	0.01 f/cc
WL-47	2층 1-7b	14.45	90	1,300.5	10	0.0038	0.01 f/cc
WL-48	2층 1-7c	14.44	90	1,299.6	9	0.0034	0.01 f/cc
WL-49	2층 1-3a	14.45	90	1,300.5	12	0.0045	0.01 f/cc
WL-50	2층 1-3b	14.51	90	1,305.9	13	0.0049	0.01 f/cc
WL-51	2층 1-3c	14.47	90	1,302.3	13	0.0049	0.01 f/cc
WL-52	2층 돌봄교실a	14.44	90	1,299.6	10	0.0038	0.01 f/cc
WL-53	2층 돌봄교실b	14.46	90	1,301.4	10	0.0038	0.01 f/cc
WL-54	2층 돌봄교실c	14.45	90	1,300.5	9	0.0034	0.01 f/cc
WL-55	1층 복도a	13.48	90	1,213.2	15	0.0061	0.01 f/cc
WL-56	1층 복도b	13.52	90	1,216.8	14	0.0056	0.01 f/cc
WL-57	1층 복도c	13.55	90	1,219.5	15	0.0060	0.01 f/cc
WL-58	1층 복도d	13.59	90	1,223.1	13	0.0052	0.01 f/cc
WL-59	1층 연구실a	13.57	90	1,221.3	13	0.0052	0.01 f/cc
WL-60	1층 연구실b	13.54	90	1,218.6	12	0.0048	0.01 f/cc

석면농도측정 결과표

(Asbestos and other fibers by PCM)

[illegible]