

[별지서식]

학교 환경위생 및 식품위생(정기·특별) 점검표

1. 개요

학 교 명		이리고현초등학교		교 장		이정숙	
소 재 지		전북 익산시 선화로23길 44					
설립구분		1949년 10월 04일		교 실 수		일반 (13실), 특별(26실)	
전화번호		063-857-9209		FAX 번호			
설비 현황	냉방	중앙 : 실, 개별 : 실		먹는물 시설	먹는물	상수도	
	난방	중앙 : 실, 개별 : 실			저수조	개	
	환기	중앙 : 실, 개별 : 실			정수기	개 (먹는샘물 : 개)	
급식시설		조리실 (○) 식당 (○)		체육장	() 종류 :		
체육관 및 강당		체육관 : 실 강당 : 1실		기숙사	() 신축(증개축)년도 : 년		

2. 학교 실내환경 측정개요

① 측정일자	2023. 10. 30	②측정시간	13:00 ~ 14:30
③ 측정장소	행정실, 교무실, 보건실, 급식실, 강당, 6-1, 유치원, 영어체험실, 전산실, 체육교사실		
④ 측정자	(소속) 푸른환경연구소㈜ (성명) 박시호		
⑤ 측정조건	건축물 및 교실의 특성 : 철근콘크리트슬라브건물 측정지점(교사 평면도에 표기) : 측정지점 교사 평면도 표기 환기장치 : 자연환기상태 외기상태 : 정상		

측정 항목	검사조건		검사 횟수	검사결과			유지 기준	평가 결과	측정기기 사양					검사 방법	비고
	검사장소	검사시간		최소	최대	평균			제조회사	모델명	제작일	고유번호	성능검사일		
오존 (ppm)	행정실	13:00~14:30	3	0.02	0.02	0.02	0.06	적합	Gray wolf	IQ-610Xtra	2008.09.16.	05-2765	2023.01.05	직독식	
	교무실	13:00~14:30	3	0.02	0.02	0.02		적합							
진드기 등 (마리/m²)	보건실	13:00~14:30	1	20마리 미만			100	적합	ASAN PHARM	Asan Easy Test Mite-Check	-	DBW031a	-	간이측정법	


3-2 교사안에서의 공기질 외 항목

측정 항목	검사조건		검사 횟수	검사결과			유지 기준	평가 결과	측정기기 사양					검사 방법	비고
	검사 장소	검사 시간		최소	최대	평균			제 조 회 사	모 델 명	제 작 일	고 유 번 호	성 능 검 사 일		
환기 (m³/h)	전산실	13:00~14:30	3	55.7	64.7	60.2	1인당 환기량 21.6m³/h 이상	적합	Gray wolf	IQ-610 Xtra	2008.09.16.	05-2765	2023.01.05	직독식	
	6-2	13:00~14:30	3	58.3	68.3	63.3		적합							
	유치원	13:00~14:30	3	31.2	35.2	33.2		적합							
조도 (책상면) (lux)	전산실	13:00~14:30	3	776	779	777	최대조도 최소조도의 비 3:1 이하	조도비 1.003	Tenmars	TM-208	2019.6.13	171104611		직독식	
	6-2	13:00~14:30	3	718	722	720		조도비 1.005							
	유치원	13:00~14:30	3	727	733	730		조도비 1.008							
조도 (칠판면) (lux)	전산실	13:00~14:30	3	781	785	783	최대조도 최소조도의 비 3:1 이하	조도비 1.005	Tenmars	TM-208	2019.6.13	171104611		직독식	
	6-2	13:00~14:30	3	734	737	735		조도비 1.004							
	유치원	13:00~14:30	3	730	733	731		조도비 1.004							
실내온도 (℃)	전산실	13:00~14:30	3	24.3	24.3	24.3	18 ~ 28	적합	Gray wolf	IQ-610 Xtra	2008.09.16.	05-2765	2023.01.05	직독식	
	6-2	13:00~14:30	3	25.1	25.1	25.1		적합							
	유치원	13:00~14:30	3	27.7	27.7	27.7		적합							
습도 (%)	전산실	13:00~14:30	3	40	40	40	30 ~ 80	적합	Gray wolf	IQ-610 Xtra	2008.09.16.	05-2765	2023.01.05	직독식	
	6-2	13:00~14:30	3	51	51	51		적합							
	유치원	13:00~14:30	3	41	41	41		적합							
소음 (dB)	전산실	13:00~14:30	3	45	48	46	55	적합	Giltro n	GTS390	2019.6.13	180809481		직독식	
	영어실	13:00~14:30	3	41	43	42		적합							

위와 같이 측정 분석결과를 사실대로 기록합니다.

2023년 11월 13일

상 호 : 푸른환경연구회(주)
대표자 : 송승용



2023년도 이리고현초등학교 각 실 배정표

The diagram is a detailed floor plan of the 1st floor of the Gyeongju National Museum. It shows a complex arrangement of rooms, including exhibition halls, offices, and public spaces. The plan is color-coded to distinguish between different types of rooms: blue for exhibition halls, green for offices, yellow for public spaces, and red for circulation areas. The layout includes a large central hall, several smaller exhibition spaces, and a series of offices along the perimeter. The plan also shows the location of the entrance, the auditorium, and the library. A legend in the bottom right corner identifies the room types, and a scale bar is provided for reference.